



The Public Health and Safety Organization

NSF Product and Service Listings

These NSF Official Listings are current as of **Thursday, June 19, 2014** at 12:15 a.m. Eastern Time. Please contact [NSF International](#) to confirm the status of any Listing, report errors, or make suggestions.

Alert: NSF is concerned about fraudulent downloading and manipulation of website text. Always confirm this information by clicking on the below link for the most accurate information: <http://info.nsf.org/Certified/PwsComponents/Listings.asp?Company=C0024420&Standard=061&>

NSF/ANSI 61 Drinking Water System Components - Health Effects

NOTE: Unless otherwise indicated for Materials, Certification is only for the Water Contact Material shown in the Listing. Click here for a list of Abbreviations used in these Listings.

Great Lakes Copper Inc.

1010 Clarke Road

London, ON N5Y 5S6

Canada

800-561-7119

519-455-0770

[Visit this company's website \(http://www.wlvtc.com\)](http://www.wlvtc.com)

Facility : London, Ontario, Canada

Pipes and Related Products

Trade Designation	Size	Water Contact Temp	Water Contact Material
Pipe[1] [G] Great Lakes Copper	1/4" - 4"	C. HOT	CU

[1] Copper tube (Alloy C12200) is Certified by NSF to NSF/ANSI 61 for use in drinking water supplies of pH 6.5 and above. Drinking water supplies that are less than pH 6.5 may require corrosion control to limit leaching of copper into the drinking water.

[G] Product is Certified to NSF/ANSI 372 and conforms with the lead content requirements for "lead free" plumbing as defined by California, Vermont, Maryland, and Louisiana state laws and the U.S. Safe Drinking Water Act.

Number of matching Manufacturers is 1

Number of matching Products is 1

Processing time was 0 seconds